

# Punjab State AIDS Control Society

(Department of Health & Family Welfare)  
Level IV, Prayaas Building, Sector 38-B, Chandigarh,  
Ph No. 0172-2636802, Fax No. 0172-2636791

E-mail: [punjabacs@gmail.com](mailto:punjabacs@gmail.com)

PSACS/Proc/2020-21/ 597

Dated: 23/7/2020

Chandigarh

**Subject: Clarification for Pre Bid queries for installation of walk in cooler/cold rooms in health facilities of Punjab**

Q	Query Raised by Bidder	Reply/Remarks																								
1	What should be the sheet thickness for flooring as the common sheet thickness for the flooring insulation mentioned at Sr no. 6 of cold room specifications is 0.5 mm.	NACO Guidelines to be followed:- Minimum 80mm PUF Panel with outer side 0.7mm PPGI.																								
2	For the five cold rooms mentioned in the tender documents the area of the second, fourth and fifth i.e. Bathinda, Gurdaspur and Fazilka respectively does not match with the cooling capacity mentioned in the specifications. A query was raised whether for the bigger size at Fazilka can have only one cold room or can two or more cold rooms be adjusted according to the cooling capacity and if the sizes remains the same then what should be the cooling capacity for each cold room.	Single cold room at each site for given size with the cooling capacity and the size of the cold room should be maximum as per table below with variation of +/- 10% <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Category</th> <th>Size (L*W*H) in Ft.</th> <th>Cooling Capacity (BTU/Hr.) (min)</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>12*12*8.5</td> <td>18,000</td> </tr> <tr> <td>B</td> <td>14*14*8.5</td> <td>18,000</td> </tr> <tr> <td>C</td> <td>16*10*8.5</td> <td>24,000</td> </tr> <tr> <td>D</td> <td>16*15*8.5</td> <td>24,000</td> </tr> <tr> <td>E</td> <td>20*16*8.5</td> <td>30,000</td> </tr> <tr> <td>F</td> <td>10*10*8.5</td> <td>16,000</td> </tr> <tr> <td>G</td> <td>14*8*8.5</td> <td>18,000</td> </tr> </tbody> </table>	Category	Size (L*W*H) in Ft.	Cooling Capacity (BTU/Hr.) (min)	A	12*12*8.5	18,000	B	14*14*8.5	18,000	C	16*10*8.5	24,000	D	16*15*8.5	24,000	E	20*16*8.5	30,000	F	10*10*8.5	16,000	G	14*8*8.5	18,000
Category	Size (L*W*H) in Ft.	Cooling Capacity (BTU/Hr.) (min)																								
A	12*12*8.5	18,000																								
B	14*14*8.5	18,000																								
C	16*10*8.5	24,000																								
D	16*15*8.5	24,000																								
E	20*16*8.5	30,000																								
F	10*10*8.5	16,000																								
G	14*8*8.5	18,000																								
3	The exact number of racks to be in a single cold room should be mentioned and place of racks	NACO Guidelines to be followed. Each Rack size (Approx):-1200(W)*600(D)*2000(H)mm. to be placed along with walls of cold room.																								
4	The height of rack has to be specifically mentioned as there was confusion of six feet and 2000 mm.	NACO Guidelines to be followed. Stainless steel fully adjustable racks for Stacking or Storage fitted on all Walls up to 6 ft. height.																								
5	What should be height of kick plate?	Kick plate is on both side of the Door to protect the door during material handling should be 2 feet																								
6	The bidders suggested that the refrigeration unit and PUF panel should be of the same manufacturer. Clarification is sought for the incorporation of suggestion	Manufacturer of refrigeration unit and PUF panel may vary but it should not compromise specifications.																								
7	Clarification is seek that whether the firm has to be in total L1 for all five cold rooms or could be individual L1.	Individual L1 to be taken.																								
8	The bidders have requested that there should not be any seepage from the roof, walls or floor where the cold room has to be installed.	SMO I/C s of the health facilities may be asked to ensure no possibility of short circuit, leakage, seepage etc exists before the initiation of installation work.																								
9	What should be the size of LCD display logger	Size of display logger be 10 inch x 12 inch																								
10	The aluminium chequered flooring mentioned in specification is of 2 mm while commonly used in market aluminium chequered flooring is of 1.2 mm. Clarification has been sought for this whether to use 1.2 mm or 2.0 mm	NACO guidelines to be followed. Aluminum Chequered plate of 2mm.																								
11	The bidders have seeked Clarification for the No Conviction Certificate from licensing authority	NACO guidelines are self explanatory regarding no conviction certificate i.e. Affidavit should be submitted by agency that "the agency has not been blacklisted by the GOI, State Govt, or any other Govt. owned agency including Quasi-Govt sector organization or company for corrupt, fraudulent practices or reasons related to non-performance in an engagement on the date of opening of RFP.( Self attested copy of Affidavit duly attested by Notary Public to be furnished."																								

  
**Additional Project Director**  
**Punjab State AIDS Control Society**  
